## **SIEMENS**

## **Data sheet**

## 6ES7416-2FP07-0AB0



SIMATIC S7-400, CPU 416F-2, Central processing unit with: Work memory 8 MB, (4 MB code, 4 MB data), 1st interface MPI/DP 12 Mbit/s, 2nd interface PROFIBUS DP,

General information	
Product type designation	CPU 416F-2
HW functional status	01
Firmware version	V7.0
Product function	
Isochronous mode	Yes; For PROFIBUS only
Engineering with	
<ul> <li>Programming package</li> </ul>	STEP 7 V5.4 or higher with HSP 261
CiR - Configuration in RUN	
CiR synchronization time, basic load	100 ms
CiR synchronization time, time per I/O byte	10 μs
Supply voltage	
Rated value (DC)	Power supply via system power supply
Input current	
from backplane bus 5 V DC, typ.	0.9 A
from backplane bus 5 V DC, max.	1.1 A
from backplane bus 24 V DC, max.	300 mA; 150 mA per DP interface
from interface 5 V DC, max.	90 mA; At each DP interface
Power loss	
Power loss, typ.	4.5 W
Power loss, max.	5.5 W
Memory	
Type of memory	RAM
Work memory	
• integrated	8 Mbyte
<ul><li>integrated (for program)</li></ul>	4 Mbyte
<ul><li>integrated (for data)</li></ul>	4 Mbyte
expandable	No
Load memory	
<ul><li>expandable FEPROM</li></ul>	Yes; with Memory Card (FLASH)
<ul> <li>expandable FEPROM, max.</li> </ul>	64 Mbyte
<ul><li>integrated RAM, max.</li></ul>	1 Mbyte
expandable RAM	Yes; with Memory Card (RAM)
expandable RAM, max.	64 Mbyte
Backup	
• present	Yes
<ul><li>with battery</li></ul>	Yes; all data
without battery	No
Battery	
Backup battery	

<ul> <li>Backup current, typ.</li> </ul>	180 μA; up to 40 °C
Backup current, max.	850 μA
Backup time, max.	Dealt with in the module data manual with the secondary conditions and the factors of influence
<ul> <li>Feeding of external backup voltage to CPU</li> </ul>	5 V DC to 15 V DC
CPU processing times	
for bit operations, typ.	12.5 ns
for word operations, typ.	12.5 ns
for fixed point arithmetic, typ.	12.5 ns
for floating point arithmetic, typ.	25 ns
CPU-blocks	
DB	
<ul> <li>Number, max.</li> </ul>	10 000; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
<ul><li>Number, max.</li></ul>	5 000; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
<ul><li>Number, max.</li></ul>	5 000; Number range: 0 to 7999
• Size, max.	64 kbyte
ОВ	
Number, max.	see instruction list
• Size, max.	64 kbyte
Number of free cycle OBs	1; OB 1
Number of time alarm OBs	8; OB 10-17
Number of delay alarm OBs	4; OB 20-23
Number of cyclic interrupt OBs	9; OB 30-38 (shortest cycle that can be set = 500 μs)
Number of process alarm OBs	8; OB 40-47
Number of DPV1 alarm OBs	3; OB 55-57
Number of isochronous mode OBs	4; OB 61-64
Number of multicomputing OBs	1; OB 60
Number of background OBs	1; OB 90
Number of startup OBs	2; OB 100, 102
Number of asynchronous error OBs	9; OB 80-88
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
per priority class	24
additional within an error OB	2
Counters, timers and their retentivity	
S7 counter	0.010
• Number	2 048
Retentivity	W
— adjustable	Yes
— lower limit	0
— upper limit	2 047 Z 0 to Z 7
— preset	201021
Counting range  — lower limit	0
— lower limit — upper limit	999
— upper limit IEC counter	
• present	Yes
• Type	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	Chiminica (infinited this by Fativi capacity)
• Number	2 048
Retentivity	€ 010
— adjustable	Yes
— lower limit	0
— upper limit	2 047
— preset	No times retentive
Time range	uniod totoliuto
Time range	

Louise limit	40
— lower limit	10 ms
— upper limit  IEC timer	9 990 s
	V
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	Total working and load memory (with backup battery)
Flag	
• Size, max.	16 kbyte; Size of bit memory address area
Retentivity available	Yes
Retentivity preset	MB 0 to MB 15
Number of clock memories	8; in 1 memory byte
Local data	
<ul><li>adjustable, max.</li></ul>	32 kbyte
• preset	16 kbyte
Address area	
I/O address area	
• Inputs	16 kbyte
Outputs	16 kbyte
Process image	
<ul> <li>Inputs, adjustable</li> </ul>	16 kbyte
<ul> <li>Outputs, adjustable</li> </ul>	16 kbyte
<ul> <li>Inputs, default</li> </ul>	512 byte
Outputs, default	512 byte
<ul> <li>consistent data, max.</li> </ul>	244 byte
<ul> <li>Access to consistent data in process image</li> </ul>	Yes
Subprocess images	
<ul> <li>Number of subprocess images, max.</li> </ul>	15
Digital channels	
• Inputs	131 072
— of which central	131 072
<ul> <li>Outputs</li> </ul>	131 072
— of which central	131 072
Analog channels	
• Inputs	8 192
— of which central	8 192
Outputs	8 192
— of which central	8 192
Hardware configuration	0.102
Number of expansion units, max.	21
connectable OPs	95
Multicomputing	Yes; 4 CPUs max. (with UR1 or UR2)
Interface modules	160, 4 OF US HIAX. (WILLI OIXT OF UKZ)
Number of connectable IMs (total), max.	6
<ul> <li>Number of connectable IM 460s, max.</li> <li>Number of connectable IM 463s, max.</li> </ul>	6 4; IM 463-2
	4, IIVI 403-2
Number of DP masters	2
• integrated	2 10: CD 4/3 5 Evtonded
• via CP	10; CP 443-5 Extended
• via IM 467	No: IM 467 connet be used is inthoughth CD 442.5 Ext. or CD 442.1 in
Mixed mode IM + CP permitted	No; IM 467 cannot be used jointly with CP 443-5 Ext. or CP 443-1 in PROFINET IO mode
via interface module	0
Number of pluggable S5 modules (via adapter capsule in central device), max.	6
Number of IO Controllers	
• integrated	0
• via CP	4; Max. 4 in the central controller; no mixed operation of different CP 443-1
	types in PROFINET IO mode
Number of operable FMs and CPs (recommended)	

• FM	Limited by number of slots and number of connections
• CP, PtP	CP 440: Limited by number of slots; CP 441: limited by number of connections
PROFIBUS and Ethernet CPs	14; In total max. 10 CPs as DP master and PROFINET controller, of which up to 10 IMs or CPs as DP master and up to 4 CPs as PROFINET controller
Slots	
required slots	1
Time of day	
Clock	
<ul> <li>Hardware clock (real-time)</li> </ul>	Yes
<ul> <li>retentive and synchronizable</li> </ul>	Yes
<ul> <li>Resolution</li> </ul>	1 ms
<ul> <li>Deviation per day (buffered), max.</li> </ul>	1.7 s; Power off
Deviation per day (unbuffered), max.	8.6 s; For power On
Operating hours counter	
Number	16
<ul> <li>Number/Number range</li> </ul>	0 to 15
Range of values	SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours
Granularity	1 h
retentive	Yes
Clock synchronization	
<ul><li>supported</li></ul>	Yes
• to MPI, master	Yes
● to MPI, slave	Yes
● to DP, master	Yes
to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	No; Via CP
● to IF 964 DP	No No
Time difference in system when synchronizing via	
MPI, max.	200 ms
Interfaces	
Interfaces/bus type	1 x MPI/PROFIBUS DP, 1 x PROFIBUS DP
Number of RS 485 interfaces	1 x MPI/PROFIBUS DP, 1 x PROFIBUS DP 2; Combined MPI / PROFIBUS DP and PROFIBUS DP
Number of RS 485 interfaces  I. Interface	2; Combined MPI / PROFIBUS DP and PROFIBUS DP
Number of RS 485 interfaces  I. Interface  Interface type	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP
Number of RS 485 interfaces  I. Interface  Interface type  Isolated	2; Combined MPI / PROFIBUS DP and PROFIBUS DP
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  • RS 485	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes
Number of RS 485 interfaces  Interface Interface type Isolated Interface types  • RS 485  • Output current of the interface, max.	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  • RS 485  • Output current of the interface, max.  Protocols	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes
Number of RS 485 interfaces  I. Interface  Interface type  Isolated  Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master  • PROFIBUS DP slave	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA
Number of RS 485 interfaces  I. Interface  Interface type  Isolated  Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master  • PROFIBUS DP slave  MPI	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes
Number of RS 485 interfaces  I. Interface  Interface type  Isolated  Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master  • PROFIBUS DP slave	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master  • PROFIBUS DP slave  MPI	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master  PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  RS 485 Output current of the interface, max.  Protocols MPI PROFIBUS DP master PROFIBUS DP slave  MPI Number of connections Transmission rate, max.  Services — PG/OP communication — Routing	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type Isolated Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication Routing Global data communication	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485  Output current of the interface, max.  Protocols  MPI  PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication Routing Global data communication S7 basic communication S7 communication	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485 Output current of the interface, max.  Protocols MPI PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication Routing Global data communication S7 basic communication S7 communication S7 communication, as client	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485 Output current of the interface, max.  Protocols  MPI PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication Routing Global data communication S7 basic communication S7 communication S7 communication, as client S7 communication, as server	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
Number of RS 485 interfaces  Interface  Interface type  Isolated  Interface types  RS 485 Output current of the interface, max.  Protocols MPI PROFIBUS DP master PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  PG/OP communication Routing Global data communication S7 basic communication S7 communication S7 communication, as client	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA   44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1  12 Mbit/s  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Y
Number of RS 485 interfaces  1. Interface Interface type Isolated Interface types  • RS 485  • Output current of the interface, max.  Protocols  • MPI  • PROFIBUS DP master  • PROFIBUS DP slave  MPI  • Number of connections  • Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master	2; Combined MPI / PROFIBUS DP and PROFIBUS DP  MPI/PROFIBUS DP  Yes  Yes  150 mA  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye

Services	
— PG/OP communication	Yes
PG/OP communication      Routing	Yes; S7 routing
-	
— Global data communication	No Yes
— S7 basic communication	
— S7 communication	Yes
— S7 communication, as client	Yes
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	Yes
— SYNC/FREEZE	Yes
Activation/deactivation of DP slaves	Yes
<ul> <li>— Direct data exchange (slave-to-slave communication)</li> </ul>	Yes
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Inputs, max. — Outputs, max.	2 kbyte
	2 noyle
User data per DP slave	244 buto
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
PROFIBUS DP slave	
<ul> <li>Number of connections</li> </ul>	32
• GSD file	http://support.automation.siemens.com/WW/view/en/113652
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s
<ul> <li>automatic baud rate search</li> </ul>	No
<ul> <li>Address area, max.</li> </ul>	32; Virtual slots
<ul> <li>User data per address area, max.</li> </ul>	32 byte
— of which consistent, max.	32 byte
Services	
— PG/OP communication	Yes; with interface active
— Routing	Yes; with interface active
<ul> <li>Global data communication</li> </ul>	No
<ul> <li>S7 basic communication</li> </ul>	No
— S7 communication	Yes
<ul> <li>— S7 communication, as client</li> </ul>	Yes
<ul> <li>S7 communication, as server</li> </ul>	Yes
<ul> <li>Direct data exchange (slave-to-slave</li> </ul>	No
communication)	
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	PROFIBUS DP
Isolated	Yes
Number of connection resources	32
Interface types	
• RS 485	Yes
Output current of the interface, max.	150 mA
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP slave	Yes
PROFIBUS DP master	
Number of connections, max.	32
Transmission rate, max.  Transmission rate, max.	12 Mbit/s
<ul><li>Transmission rate, max.</li><li>Number of DP slaves, max.</li></ul>	12 Molius 125
	1EU
Services	

— PG/OP communication	Yes
Routing     Global data communication	Yes; S7 routing No
— S7 basic communication	Yes
— S7 communication	Yes
— S7 communication  — S7 communication, as client	Yes
— S7 communication, as circle  — S7 communication, as server	Yes
— Equidistance	Yes
Equidistance      Isochronous mode	Yes
— SYNC/FREEZE	Yes
Activation/deactivation of DP slaves	Yes
Activation/deactivation of DF slaves      Direct data exchange (slave-to-slave)	Yes
communication)	165
— DPV1	Yes
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
User data per DP slave	
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
PROFIBUS DP slave	
Number of connections	32
• GSD file	http://support.automation.siemens.com/WW/view/en/113652
Transmission rate, max.	12 Mbit/s
Address area, max.	32
User data per address area, max.	32 byte
— of which consistent, max.	32 byte
Services	
— Routing	Yes; with interface active
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
Protocols	
SIMATIC communication	
S7 routing	Yes
Open IE communication	
• ISO-on-TCP (RFC1006)	Via CP 443-1 and loadable FB
— Data length, max.	1 452 bytes via CP 443-1 Adv.
Web server	
<ul><li>supported</li></ul>	No
Isochronous mode	
Equidistance	Yes
Number of DP masters with isochronous mode	2
User data per isochronous slave, max.	244 byte
shortest clock pulse	1 ms; 0.5 ms without use of SFC 126, 127
max. cycle	32 ms
communication functions / header	
PG/OP communication	Yes
<ul> <li>Number of connectable OPs without message processing</li> </ul>	95
Number of connectable OPs with message processing	95; When using Alarm_S/SQ and Alarm_D/DQ
Data record routing	Yes
Global data communication	
• supported	Yes
<ul> <li>Number of GD loops, max.</li> </ul>	16
<ul> <li>Number of GD packets, transmitter, max.</li> </ul>	16
<ul> <li>Number of GD packets, receiver, max.</li> </ul>	32
<ul> <li>Size of GD packets, max.</li> </ul>	54 byte
<ul> <li>Size of GD packet (of which consistent), max.</li> </ul>	1 variable
• Size of GD packet (of which consistent), max.	

07 h - i	
S7 basic communication	
communication function / S7 basic communication	Yes
User data per job, max.	76 byte
User data per job (of which consistent), max.	1 variable
S7 communication	
• supported	Yes
• as server	Yes
• as client	Yes
<ul> <li>User data per job, max.</li> </ul>	64 kbyte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	462 byte; 1 variable
S5 compatible communication	
• supported	Yes; Via FC AG_SEND and AG_RECV, max. via 10 CP 443-1 or 443-5
<ul> <li>User data per job, max.</li> </ul>	8 kbyte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	240 byte
<ul> <li>Number of simultaneous AG-SEND/AG-RECV orders per CPU, max.</li> </ul>	64/64
Standard communication (FMS)	
• supported	Yes; Via CP and loadable FB
Number of connections	
overall	96
usable for PG communication	95
<ul> <li>reserved for PG communication</li> </ul>	1
<ul> <li>adjustable for PG communication, max.</li> </ul>	0
usable for OP communication	95
<ul> <li>reserved for OP communication</li> </ul>	1
<ul> <li>adjustable for OP communication, max.</li> </ul>	0
usable for S7 basic communication	94
reserved for S7 basic communication	0
adjustable for S7 basic communication, max.	0
usable for S7 communication	94
reserved for S7 communication	0
adjustable for S7 communication, max.	0
usable for routing	47
reserved for routing	0
-	0
adjustable for routing, max.  S7 message functions	
	05 M 05 'II AI 0/00 I AI D/D0 (0D ) 40 'II AI
Number of login stations for message functions, max.	95; Max. 95 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 16 with Alarm, Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC)
Symbol-related messages	Yes
SCAN procedure	Yes
Program alarms	Yes
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	1 000; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks
Alarm 8-blocks	Yes
<ul> <li>Number of instances for alarm 8 and S7 communication blocks, max.</li> </ul>	4 000
• preset, max.	600
Process control messages	Yes
Number of archives that can log on simultaneously (SFB 37 AR_SEND)	32
Number of messages	
• overall, max.	1 024
● in 100 ms grid, max.	128
• in 500 ms grid, max.	512
● in 1000 ms grid, max.	1 024
Number of additional values	
• with 100 ms grid, max.	1
• with 500, 1000 ms grid, max.	10
Test commissioning functions	
Status block	Yes; Up to 16 simultaneously
Single step	Yes
Number of breakpoints	16

Status/control	
Status/control variable	Yes; Up to 16 variable tables
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	70; Status/control
Forcing	10, old do oon do
Forcing	Yes
Forcing, variables	Inputs, outputs, bit memories, peripheral inputs, peripheral outputs
Number of variables, max.	512
Diagnostic buffer	012
• present	Yes
Number of entries, max.	3 200
— adjustable	Yes
— preset	120
Service data	
• can be read out	Yes
Standards, approvals, certificates	
CE mark	Yes
CSA approval	Yes
UL approval	Yes
cULus	Yes
FM approval	Yes
RCM (formerly C-TICK)	Yes
KC approval	Yes
EAC (formerly Gost-R)	Yes
Use in hazardous areas	
• ATEX	ATEX II 3G Ex nA IIC T4 Gc
Ambient conditions	ALEXII GO EXTINUIO 11 GO
Ambient temperature during operation	
min.	0 °C
• max.	60 °C
configuration / header	
Configuration / header	
Configuration software	Yes
Configuration software  • STEP 7	Yes
Configuration software  • STEP 7  configuration / programming / header	
Configuration software  • STEP 7  configuration / programming / header  • Command set	see instruction list
Configuration software  • STEP 7  configuration / programming / header  • Command set  • Nesting levels	see instruction list
Configuration software  • STEP 7  configuration / programming / header  • Command set  • Nesting levels  • Access to consistent data in process image	see instruction list 7 Yes
Configuration software  • STEP 7  configuration / programming / header  • Command set  • Nesting levels  • Access to consistent data in process image  • System functions (SFC)	see instruction list 7 Yes see instruction list
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)	see instruction list 7 Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language	see instruction list 7 Yes see instruction list
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)	see instruction list 7 Yes see instruction list see instruction list
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD	see instruction list 7 Yes see instruction list see instruction list Yes Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously actives  DPSYC_FR	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously actives  DPSYC_FR  D_ACT_DP	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active — DPSYC_FR  D_ACT_DP  RD_REC	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active  DPSYC_FR  D_ACT_DP  RD_REC  WR_REC	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active — DPSYC_FR  D_ACT_DP  RD_REC  WR_PARM	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active — DPSYC_FR  D_ACT_DP  RD_REC  WR_PARM  PARM_MOD	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active  DPSYC_FR  D_ACT_DP  RD_REC  WR_REC  WR_PARM  PARM_MOD  WR_DPARM	see instruction list 7 Yes see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active of the configuration in the configuration i	see instruction list 7 Yes see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active — DPSYC_FR  D_ACT_DP  RD_REC  WR_REC  WR_PARM  PARM_MOD  WR_DPARM  DPNRM_DG  RDSYSST	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active  DPSYC_FR  D_ACT_DP  RD_REC  WR_REC  WR_PARM  PARM_MOD  WR_DPARM  DPNRM_DG  RDSYSST  DP_TOPOL	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Configuration software  STEP 7  configuration / programming / header  Command set  Nesting levels  Access to consistent data in process image  System functions (SFC)  System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active — DPSYC_FR  D_ACT_DP  RD_REC  WR_REC  WR_PARM  PARM_MOD  WR_DPARM  DPNRM_DG  RDSYSST	see instruction list 7 Yes see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

— WRREC	8; SFB 53; per interface, but not more than 32 across all external interfaces
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
<ul> <li>Block encryption</li> </ul>	Yes; With S7 block Privacy
Dimensions	
Width	25 mm
Height	290 mm
Depth	219 mm
Weights	
Weight, approx.	700 g

last modified: 9/7/2023 🖸