## **SIEMENS**

## **Data sheet**

## 6ES7417-5HT06-0AB0



SIMATIC S7-400H, CPU 417-5H, central processing unit for S7-400H and S7-400F/FH, 5 interfaces: 1x MPI/DP, 1x DP, 1x PN and 2 for sync modules, 32 MB memory (16 MB data/16 MB program)

General information	
Product type designation	CPU 417-5H PN/DP
HW functional status	1
Firmware version	V6.0
Product function	
Isochronous mode	No
Engineering with	
<ul> <li>Programming package</li> </ul>	As of STEP 7 V5.5 SP2 with HF1
CiR - Configuration in RUN	
CiR synchronization time, basic load	60 ms
CiR synchronization time, time per I/O byte	0 μs
Supply voltage	
Rated value (DC)	Power supply via system power supply
Input current	
from backplane bus 5 V DC, typ.	1.6 A
from backplane bus 5 V DC, max.	1.9 A
from backplane bus 24 V DC, max.	150 mA; 150 mA per DP interface
from interface 5 V DC, max.	90 mA; At each DP interface
Power loss	
Power loss, typ.	7.5 W
Memory	
Type of memory	RAM
Work memory	
<ul><li>integrated</li></ul>	32 Mbyte
<ul><li>integrated (for program)</li></ul>	16 Mbyte
<ul><li>integrated (for data)</li></ul>	16 Mbyte
expandable	No
Load memory	
<ul> <li>expandable FEPROM</li> </ul>	Yes; with Memory Card (FLASH)
<ul> <li>expandable FEPROM, max.</li> </ul>	64 Mbyte
<ul><li>integrated RAM, max.</li></ul>	1 Mbyte
<ul> <li>expandable RAM</li> </ul>	Yes
expandable RAM, max.	64 Mbyte
Backup	
• present	Yes
<ul><li>with battery</li></ul>	Yes; all data
without battery	No
Battery	
Backup battery	
<ul> <li>Backup current, typ.</li> </ul>	180 μA; Valid up to 40°C

	4000
Backup current, max.	1 000 μΑ
Backup time, max.	Dealt with in the module data manual with the secondary conditions and the factors of influence
<ul> <li>Feeding of external backup voltage to CPU</li> </ul>	5 V DC to 15 V DC
CPU processing times	
for bit operations, typ.	7.5 ns
for word operations, typ.	7.5 ns
for fixed point arithmetic, typ.	7.5 ns
for floating point arithmetic, typ.	15 ns
CPU-blocks	
DB	
Number, max.	16 000; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	8 000; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
<ul><li>Number, max.</li></ul>	8 000; Number range: 0 to 7999
• Size, max.	64 kbyte
ОВ	
<ul> <li>Number, max.</li> </ul>	see instruction list
• Size, max.	64 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	1; OB 1
<ul> <li>Number of time alarm OBs</li> </ul>	8; OB 10-17
<ul> <li>Number of delay alarm OBs</li> </ul>	4; OB 20-23
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	9; OB 30-38
<ul> <li>Number of process alarm OBs</li> </ul>	8; OB 40-47
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3; OB 55-57
<ul> <li>Number of startup OBs</li> </ul>	2; OB 100, 102
<ul> <li>Number of asynchronous error OBs</li> </ul>	9; OB 80-88
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
per priority class	24
additional within an error OB	2
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	2 047
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	Von
• present	Yes
• Type	SFB Unlimited (limited only by PAM conscity)
• Number	Unlimited (limited only by RAM capacity)
S7 times  • Number	2 048
Retentivity	£ 040
— adjustable	Yes
— aujustable — lower limit	0
— upper limit	2 047
— upper limit — preset	No times retentive
— preset  Time range	140 (IIIIG9 1G(G))(IAC
·	
lower limit	10 mg
— lower limit	10 ms
— upper limit	10 ms 9 990 s

• Type	SFB
Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	Oriminited (infilted only by IVAIVI capacity)
Retentive data area (incl. timers, counters, flags), max.	Total working and load memory (with backup battery)
Flag	Total working and load memory (with backup battery)
• Size, max.	16 384 byte
Retentivity available	Yes
Retentivity available     Retentivity preset	MB 0 to MB 15
Number of clock memories	8; in 1 memory byte
Local data	c, iii - iiiciiici j sj.c
adjustable, max.	64 kbyte
• preset	32 kbyte
Address area	
I/O address area	
• Inputs	16 kbyte
Outputs	16 kbyte
Process image	
Inputs, adjustable	16 kbyte
<ul> <li>Outputs, adjustable</li> </ul>	16 kbyte
• Inputs, default	1 024 byte
Outputs, default	1 024 byte
consistent data, max.	244 byte
Access to consistent data in process image	Yes
Subprocess images	
<ul> <li>Number of subprocess images, max.</li> </ul>	15
Digital channels	
• Inputs	131 072
— of which central	131 072
<ul><li>Outputs</li></ul>	131 072
— of which central	131 072
Analog channels	
<ul><li>Inputs</li></ul>	8 192
— of which central	8 192
<ul><li>Outputs</li></ul>	8 192
— of which central	8 192
Hardware configuration	
Number of expansion units, max.	21
connectable OPs	119
Multicomputing	No
Interface modules	
Number of connectable IMs (total), max.	6
Number of connectable IM 460s, max.	6
Number of connectable IM 463s, max.	4; Single mode only
Number of DP masters	2
• integrated	2 40: CD 442 5 Extended
• via CP	10; CP 443-5 Extended
Mixed mode IM + CP permitted     via interface module	No
via interface module     Number of IO Controllers	0
	1
<ul><li>integrated</li><li>via CP</li></ul>	0
Number of operable FMs and CPs (recommended)	V
FM      FM	See manual Automation System S7-400H fault-tolerant systems. Limited by
• 1 W	number of slots and number of connections
• CP, PtP	See manual Automation System S7-400H fault-tolerant systems. Limited by
	number of slots and number of connections
PROFIBUS and Ethernet CPs	14; Of which max. 10 CP as DP master
Slots	
• required slots	2
Time of day	
Clock	

<ul> <li>Hardware clock (real-time)</li> </ul>	
	Yes
retentive and synchronizable	Yes
Resolution	1 ms
Deviation per day (buffered), max.  Periodical and day (sub-ffered), max.	1.7 s; Power off
Deviation per day (unbuffered), max.	8.6 s; Power on
Operating hours counter  • Number	16
	0 to 15
Number/Number range     Pagge of volves	
<ul><li>Range of values</li><li>Granularity</li></ul>	SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2 <sup>3</sup> 1 - 1 hours 1 h
retentive	Yes
Clock synchronization	165
• supported	Yes
• to MPI, master	Yes
• to MPI, slave	Yes
• to DP, master	Yes
• to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes; As client
Time difference in system when synchronizing via	100,710 0.001
• Ethernet, max.	10 ms; Via NTP
• MPI, max.	200 ms
Interfaces	
Number of RS 485 interfaces	2
Number of other interfaces	2; Fiber-optic interface
Optical interface	No
1. Interface	
Interface type	MPI/PROFIBUS DP
Isolated	Yes
Interface types	
• RS 485	Yes
Output current of the interface, max.	150 mA
Protocols	
• MPI	Yes
<ul> <li>PROFIBUS DP master</li> </ul>	Yes
PROFIBUS DP slave	No
	No
PROFIBUS DP slave	44; If a diagnostics repeater is used on the line, the number of connection
PROFIBUS DP slave  MPI      Number of connections	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.	44; If a diagnostics repeater is used on the line, the number of connection
<ul> <li>PROFIBUS DP slave</li> <li>MPI</li> <li>Number of connections</li> <li>Transmission rate, max.</li> <li>Services</li> </ul>	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s
PROFIBUS DP slave MPI  Number of connections  Transmission rate, max. Services — PG/OP communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes Yes Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes Yes Yes Yes Yes Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.  Number of DP slaves, max.	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.  Number of DP slaves, max.  Services	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.  Number of DP slaves, max.  Services — PG/OP communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.  Number of DP slaves, max.  Services — PG/OP communication — Routing	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes Yes Yes Yes Yes Yes Yes Yes  32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s 32  Yes Yes
PROFIBUS DP slave  MPI  Number of connections  Transmission rate, max.  Services  — PG/OP communication — Routing — Global data communication — S7 basic communication — S7 communication — S7 communication — S7 communication, as client — S7 communication, as server  PROFIBUS DP master  Number of connections, max.  Transmission rate, max.  Number of DP slaves, max.  Services  — PG/OP communication — Routing — Global data communication	44; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s  Yes Yes No No Yes

<ul> <li>S7 communication, as server</li> </ul>	Yes
— Equidistance	No
— Isochronous mode	No
— SYNC/FREEZE	No
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	No
<ul> <li>Direct data exchange (slave-to-slave communication)</li> </ul>	No
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
PROFIBUS DP slave	
Number of connections	No configuration of CPU as DP slave
2. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes; Autosensing
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	No
Number of connection resources	120
Interface types	
RJ 45 (Ethernet)	Yes
<ul> <li>Number of ports</li> </ul>	2
• integrated switch	Yes
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	No
PROFINET CBA	No
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes
Web server	No
Point-to-point connection     Modio redundancy	No Yes
Media redundancy  PROFINET IO Controller	Yes
PROFINET IO Controller	400 Mhit/s
Transmission rate, max.  Son/icea	100 Mbit/s
Services  — PG/OP communication	Voc
— PG/OP communication  — S7 communication	Yes Yes
S7 communication      Isochronous mode	res No
Isochronous mode      Shared device	Yes; Single mode only
— Prioritized startup	No
— Number of connectable IO Devices, max.	256; In redundant mode via both interfaces
Number of connectable IO Devices, max.      Number of connectable IO Devices for RT, max.	256 256
— of which in line, max.	256
Activation/deactivation of IO Devices	No
— Activation/deactivation of 10 Devices      — IO Devices changing during operation (partner)	No
ports), supported	
Device replacement without swap medium	Yes
— Send cycles	250 μs, 500 μs, 1 ms, 2 ms, 4 ms
— Updating time	250 µs to 512 ms, minimum value depends on the number of configured user data and the configured single or redundant mode
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte

	40041
User data consistency, max.  Open IF communication.	1 024 byte
Open IE communication	440
<ul><li>Number of connections, max.</li><li>Local port numbers used at the system end</li></ul>	118 0, 20, 21, 25, 102, 135, 161, 34962, 34963, 34964, 65532, 65533, 65534, 65535
Keep-alive function, supported	Yes
3. Interface	100
Interface type	PROFIBUS DP
Number of connection resources	32
Interface types	UL .
• RS 485	Yes
Output current of the interface, max.	150 mA
Protocols	100 11111
PROFIBUS DP master	Yes
PROFIBUS DP slave	No
PROFIBUS DP master	110
Number of connections, max.	32
Transmission rate, max.  Transmission rate, max.	12 Mbit/s
Number of DP slaves, max.	125
Services	120
— PG/OP communication	Yes
— Routing	Yes
— Routing  — Global data communication	No
S7 basic communication	No
— S7 communication	Yes
S7 communication  S7 communication, as client	Yes
S7 communication, as circle     S7 communication, as server	Yes
— Equidistance	No
Legardistance      Isochronous mode	No
— SYNC/FREEZE	No
Activation/deactivation of DP slaves	No
Direct data exchange (slave-to-slave communication)	No
— DPV0	Yes
— DPV1	Yes
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
User data per DP slave	
User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
4. Interface	
Interface type	Pluggable synchronization submodule (FO)
Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0
5. Interface	
Interface type	Pluggable synchronization submodule (FO)
Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0
Protocols	
Redundancy mode	
Media redundancy	
Switchover time on line break, typ.	200 ms
Number of stations in the ring, max.	50
SIMATIC communication	
• S7 routing	Yes
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
Number of connections, max.	118
— Data length, max.	32 kbyte
Sate longer, mark	-2 , 10

<ul> <li>several passive connections per port, supported</li> </ul>	Yes
• ISO-on-TCP (RFC1006)	Yes; Via integrated PROFINET interface or CP 443-1 and loadable FBs
<ul> <li>Number of connections, max.</li> </ul>	118
— Data length, max.	32 kbyte; 1 452 bytes via CP 443-1 Adv.
• UDP	Yes; via integrated PROFINET interface and loadable FBs
<ul> <li>Number of connections, max.</li> </ul>	118
— Data length, max.	1 472 byte
Web server	
<ul><li>supported</li></ul>	No
Isochronous mode	
Equidistance	No
communication functions / header	
PG/OP communication	Yes
<ul> <li>Number of connectable OPs without message processing</li> </ul>	119
Number of connectable OPs with message processing	119; When using Alarm_S/SQ and Alarm_D/DQ
Data record routing	Yes
Global data communication	
• supported	No
S7 basic communication	
communication function / S7 basic communication	No
S7 communication	
• supported	Yes
• as server	Yes
• as client	Yes
<ul> <li>User data per job, max.</li> </ul>	64 kbyte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	462 byte; 1 variable
S5 compatible communication	
• supported	Yes; (via CP max. 10 and FC AG_SEND and FC AG_RECV)
User data per job, max.	8 kbyte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	240 byte
Number of simultaneous AG-SEND/AG-RECV orders per	64/64
CPU, max.	
Standard communication (FMS)	
• supported	Yes; Via CP and loadable FB
Number of connections	
• overall	120
<ul> <li>usable for PG communication</li> </ul>	
<ul> <li>reserved for PG communication</li> </ul>	1
<ul> <li>adjustable for PG communication, max.</li> </ul>	0
<ul> <li>usable for OP communication</li> </ul>	
<ul> <li>reserved for OP communication</li> </ul>	1
<ul> <li>adjustable for OP communication, max.</li> </ul>	0
<ul> <li>usable for S7 basic communication</li> </ul>	
<ul> <li>reserved for S7 basic communication</li> </ul>	0
<ul> <li>adjustable for S7 basic communication, max.</li> </ul>	0
<ul> <li>usable for S7 communication</li> </ul>	
<ul> <li>reserved for S7 communication</li> </ul>	0
<ul> <li>adjustable for S7 communication, max.</li> </ul>	0
<ul> <li>usable for routing</li> </ul>	
— reserved for routing	0
— adjustable for routing, max.	0
S7 message functions	
Number of login stations for message functions, max.	119; max. 119 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 16 with Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC)
Symbol-related messages	No
SCAN procedure	No
Program alarms	Yes
Process diagnostic messages	Yes
1 100coo diagnostic messages	
simultaneously active Alarm-S blocks, max.	1 000; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks
	1 000; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes

blocks, max.	
• preset, max.	1 200
Process control messages	Yes
Number of archives that can log on simultaneously (SFB 37 AR_SEND)	64
Test commissioning functions	
Status block	Yes
Single step	Yes
Number of breakpoints	16
Status/control	
<ul> <li>Status/control variable</li> </ul>	Yes; Up to 16 variable tables
<ul> <li>Variables</li> </ul>	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	70
Forcing	
<ul><li>Forcing</li></ul>	Yes
<ul> <li>Forcing, variables</li> </ul>	Inputs/outputs, bit memories, distributed I/Os
Number of variables, max.	512
Diagnostic buffer	
• present	Yes
<ul> <li>Number of entries, max.</li> </ul>	3 200
— adjustable	Yes
— preset	120
Service data	
• can be read out	Yes
EMC	
Emission of radio interference acc. to EN 55 011	
Limit class A, for use in industrial areas	Yes
<ul> <li>Limit class B, for use in residential areas</li> </ul>	No
configuration / header	
Configuration software	
• STEP 7	Yes
configuration / programming / header	
Command set	see instruction list
- Necting levels	7
Nesting levels	
<ul><li>Nesting levels</li><li>Access to consistent data in process image</li></ul>	Yes
Access to consistent data in process image	Yes see instruction list
<ul><li>Access to consistent data in process image</li><li>System functions (SFC)</li></ul>	
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> </ul>	see instruction list
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> </ul>	see instruction list
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> </ul>	see instruction list see instruction list
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> </ul>	see instruction list see instruction list Yes
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> <li>FBD</li> </ul>	see instruction list see instruction list Yes Yes
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> <li>FBD</li> <li>STL</li> </ul>	see instruction list see instruction list  Yes Yes Yes
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> </ul>	see instruction list see instruction list  Yes Yes Yes Yes Yes
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> </ul>	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul>	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously activ	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously active  RD_REC  WR_REC	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously active — RD_REC — WR_REC — WR_PARM	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_PARM — PARM_MOD	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD  FBD  STL  SCL  CFC  GRAPH  HiGraph®  configuration / programming / number of simultaneously activ  RD_REC  WR_REC  WR_PARM  PARM_MOD  WR_DPARM	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD FBD STL SCL CFC GRAPH HiGraph®  configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language  — LAD  — FBD  — STL  — SCL  — CFC  — GRAPH  — HiGraph®</li> <li>configuration / programming / number of simultaneously activ  — RD_REC  — WR_REC  — WR_PARM  — PARM_MOD  — WR_DPARM  — DPNRM_DG  — RDSYSST</li> </ul>	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_PARM — PARM_MOD — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL	see instruction list see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_PARM — PARM_MOD — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL  configuration / programming / number of simultaneously activ	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_PARM — PARM_MOD — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL  configuration / programming / number of simultaneously activ — RREC	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD FBD STL SCL CFC GRAPH HiGraph®  configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL  configuration / programming / number of simultaneously active  RD_REC WR_REC WR_REC WR_REC WR_DPARM RDSYSST DP_TOPOL  configuration / programming / number of simultaneously active RDREC WRREC	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  — LAD — FBD — STL — SCL — CFC — GRAPH — HiGraph®  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_PARM — PARM_MOD — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL  configuration / programming / number of simultaneously activ — RD_REC — WR_REC — WR_DPARM — DPNRM_DG — RDSYSST — DP_TOPOL  configuration / programming / number of simultaneously activ — RDREC — WRREC  Know-how protection	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Access to consistent data in process image System functions (SFC) System function blocks (SFB)  Programming language  LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL  configuration / programming / number of simultaneously active RD_REC WR_PARM UPARM	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
<ul> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language  — LAD  — FBD  — STL  — SCL  — CFC  — GRAPH  — HiGraph®</li> <li>configuration / programming / number of simultaneously activ.  — RD_REC  — WR_REC  — WR_PARM  — PARM_MOD  — WR_DPARM  — DPNRM_DG  — RDSYSST  — DP_TOPOL  configuration / programming / number of simultaneously activ.  — RD_REC</li> </ul>	see instruction list  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

Width	50 mm
Height	290 mm
Depth	219 mm
Weights	
Weight, approx.	995 g

last modified: 9/7/2023 🖸